



NOTE 1:
FULL length of pipe
centered over SEWER

NOTE 2:
FULL length of pipe
centered over SEWER,
plus any SEWER joint
within 10' of crossing
shall be able to withstand
25 P.S.I. Internal Pressure.

NOTE 3:
When Watermain crosses UNDER the
SEWER, in all cases refer to NOTE 2.

Scale	Sheet #
NTS	1 of 1
Date	
04/07/2015	
File Name	
Construction Details.dwg	

DISCLAIMER

The specifications represented in this document are in accordance with established City of Mandan Engineering & Planning practices and are an electronic facsimile of the specifications on file in the City of Mandan Engineering & Planning Department. However, neither the City of Mandan nor its employees can or do warranty these specifications to be complete specifications for any or all construction projects. The specification document, together with all addendums listed in each construction project specification, shall be the project specification for the City of Mandan. The user acknowledges and accepts all the data "as is", including the fact that the details are under a constant state of maintenance, correction and revision.

1325-A WATER/SEWERMAIN CROSSING DETAIL

